

SECTION 15469 - DOMESTIC WATER SOFTENERS

Project Number 14-5006-39

Project title Kansas City Area Transportation Authority
Service Line Reversal (FOR INFORMATION ONLY)

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Commercial water softeners.
 - 2. Chemicals.
 - 3. Water-testing sets.

1.3 PERFORMANCE REQUIREMENTS

- A. Seismic Performance: Water softeners shall withstand the effects of earthquake motions determined according to ASCE/SEI 7.
 - 1. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified."

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
 - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for water softeners.
 - 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
 - 3. Wiring Diagrams: For power, signal, and control wiring.

1.5 INFORMATIONAL SUBMITTALS

- A. Seismic Qualification Certificates: For water softeners, accessories, and components, from manufacturer.
 - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
 - 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
 - 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
- B. Source quality-control reports.
- C. Field quality-control reports.
- D. Warranty: Sample of special warranty.

1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For water softeners to include in emergency, operation, and maintenance manuals.

1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Salt for Brine Tanks: Furnish in same form as and at least four times original load, but not less than 200 lb. Deliver on pallets according to the following:
 - a. Food-Grade Pellet Salt: In 40- or 50-lb packages.
 - b. Plain Pellet Salt: In 40- or 50-lb packages.
 - c. Crystallized Solar Salt: In 40- or 50-lb packages.
 - d. Plain, Brine Block Salt: In 50-lb blocks.
 - 2. Store salt on raised platform where directed by Owner. Do not store in contact with concrete floor.

1.8 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended application.
- B. ASME Compliance for Steel Tanks: Fabricate and label mineral tanks to comply with ASME Boiler and Pressure Vessel Code: Section VIII, Division 1, where indicated.
- C. ASME Compliance for FRP Tanks: Fabricate and label mineral tanks to comply with ASME Boiler and Pressure Vessel Code: Section X, where indicated.

- D. UL Compliance: Fabricate and label water softeners to comply with UL 979, "Water Treatment Appliances."

1.9 COORDINATION

- A. Coordinate sizes and locations of concrete bases with actual equipment provided.

1.10 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of water softeners that fail in materials or workmanship within specified warranty period.

- 1. Failures include, but are not limited to, the following:

- a. Structural failures of mineral and brine tanks.
- b. Faulty operation of controls.
- c. Deterioration of metals, metal finishes, and other materials beyond normal use.
- d. Attrition loss of resin exceeding 3 percent per year.
- e. Mineral washed out of system during service run or backwashing period.
- f. Effluent turbidity greater and color darker than incoming water.
- g. Fouling of underdrain system, gravel, and resin with turbidity or by dirt, rust, or scale from water softener or soft water, while operating according to manufacturer's written operating instructions.

- 2. Commercial Water Softeners, Warranty Period: From date of Substantial Completion.

- a. Mineral Tanks: Five years.
- b. Brine Tanks: 10 years.
- c. Control Valve: One year(s).

1.11 MAINTENANCE SERVICE

- A. Initial Maintenance Service: Beginning at Substantial Completion, provide 12 months' full maintenance by skilled employees of water softener Installer. Include quarterly preventive maintenance, repair or replacement of worn or defective components, cleaning, and adjusting as required for proper water softener operation at rated capacity. Provide parts and supplies the same as those used in the manufacture and installation of original equipment.
- B. Continuing Maintenance Proposal: From Installer to Owner, in the form of a standard yearly (or other period) maintenance agreement, starting on date initial maintenance service is concluded. State services, obligations, conditions, and terms for agreement period and for future renewal options.

PART 2 - PRODUCTS

2.1 COMMERCIAL WATER SOFTENERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. [Aquion Water Treatment Products.](#)
2. [Culligan International Company.](#)
3. [CUNO Incorporated.](#)
4. [Diamond Water Conditioning; a Griesbach company.](#)
5. [Diamond Water Systems, Inc.](#)
6. [Ecodyne Water Treatment, Inc.](#)
7. [Hungerford & Terry, Inc.](#)
8. [Integration Separation Solutions, LLC.](#)
9. [Kinetico Incorporated.](#)
10. [Marlo Incorporated.](#)
11. [Parker Boiler.](#)
12. [Springsoft International, Inc.](#)
13. [Water King.](#)
14. [WaterSoft; a division of Amtrol, Inc.](#)

- B. Description: Factory-assembled, pressure-type water softener.

1. Standard: Comply with NSF 61, "Drinking Water System Components - Health Effects."
2. Configuration: Twin unit with two mineral tanks or Triple unit with three mineral tanks and one brine tank.
3. Mounting: On skids.
4. Wetted Components: Suitable for water temperatures from 40 to at least 100 deg F.
5. Mineral Tanks: FRP, pressure-vessel quality.
 - a. Construction: Fabricated and stamped to comply with ASME Boiler and Pressure Vessel Code: Section X, "Fiber-Reinforced Plastic Pressure Vessels."
 - b. Pressure Rating: 125 psig minimum.
 - c. Freeboard: 50 percent minimum for backwash expansion above normal resin bed level.
 - d. Support Legs or Skirt: Constructed of structural steel, welded to tank before testing and labeling.
 - e. Upper Distribution System: Single, point type, fabricated from galvanized-steel pipe and fittings.
 - f. Lower Distribution System: Hub and radial-arm or header-lateral type; fabricated from nonmetallic pipe and fittings with individual, fine-slotted, nonclogging plastic strainers, and arranged for even flow distribution through resin bed.
 - g. Liner: PE, ABS, or other material suitable for potable water.
6. Mineral Tanks: Stainless steel, electric welded; pressure-vessel quality.

- a. Seismic Requirements: Fabricate supports and attachments to tank with reinforcement strong enough to resist tank movement during seismic event when tank supports are anchored to building structure.
 - b. Construction: Fabricated and stamped to comply with ASME Boiler and Pressure Vessel Code: Section VIII, "Pressure Vessels," Division 1.
 - c. Pressure Rating: 125 psig minimum.
 - d. Freeboard: 50 percent minimum for backwash expansion above normal resin bed level.
 - e. Handholes: 4 inches round or 4 by 6 inches elliptical, in top head and lower sidewall of tanks 30 inches and smaller in diameter.
 - f. Manhole: 11 by 15 inches in top head of tanks larger than 30 inches in diameter.
 - g. Support Legs or Skirt: Constructed of structural steel, welded to tank before testing and labeling.
 - h. Finish: Hot-dip galvanized on exterior and interior of tank after fabrication unless tank is stainless steel.
 - i. Finish: Exterior of tank spray-painted with rust-resistant prime coat, 2- to 3-mil dry film thickness. Interior sandblasted and lined with epoxy-polyamide coating, 8- to 10-mil dry film thickness.
 - j. Upper Distribution System: Single, point type, fabricated from galvanized-steel pipe and fittings.
 - k. Lower Distribution System: Hub and radial-arm or header-lateral type; fabricated from PVC pipe and fittings with individual, fine-slotted, nonclogging PE strainers, and arranged for even flow distribution through resin bed.
 - l. Liner: PE, ABS, or other material suitable for potable water.
7. Controls: Automatic; factory wired and factory mounted on unit.
- a. Adjustable duration of various regeneration steps.
 - b. Push-button start and complete manual operation.
 - c. Electric time clock and switch for automatic operation except for manual return to service.
 - d. Sequence of Operation: Multiport pilot-control valve automatically pressure-actuates main operating valve through steps of regeneration.
 - e. Pointer on pilot-control valve shall indicate cycle of operation.
 - f. Includes means of manual operation of pilot-control valve if power fails.
8. Controls: Fully automatic; factory wired and factory mounted on unit.
- a. Adjustable duration of various regeneration steps.
 - b. Push-button start and complete manual operation.
 - c. Electric time clock and switch for fully automatic operation, adjustable to initiate regeneration at any hour of day and any day of week or at fixed intervals.
 - d. Sequence of Operation: Multiport pilot-control valve automatically pressure-actuates main operating valve through steps of regeneration and return to service.
 - e. Pointer on pilot-control valve shall indicate cycle of operation.
 - f. Includes means of manual operation of pilot-control valve if power fails.

9. Main Operating Valves: Industrial, automatic, multiport, diaphragm type with the following features:
 - a. Slow opening and closing, nonslam operation.
 - b. Diaphragm guiding on full perimeter from fully open to fully closed.
 - c. Isolated, dissimilar metals within valve.
 - d. Self-adjusting, internal, automatic brine injector that draws brine and rinses at constant rate independent of pressure.
 - e. Valve for single mineral-tank unit with internal automatic bypass of raw water during regeneration.
 - f. Sampling cocks for soft water.
 - g. Special tools are not required for service.
10. Flow Control: Automatic, to control backwash and flush rates over wide variations in operating pressure; does not require field adjustments.
 - a. Meter Control: Each mineral tank is equipped with signal-register-head water meter that produces electrical signal indicating need for regeneration on reaching hand-set total in gallons. Signal will continue until reset.
 - b. Demand-Initiated Control: Single mineral tank is equipped with automatic-reset-head water meter that electrically activates cycle controller to initiate regeneration at preset total in gallons. Head automatically resets to preset total in gallons for next service run.
 - c. Demand-Initiated Control: Each mineral tank of twin mineral-tank unit is equipped with automatic-reset-head water meter that electrically activates cycle controllers to initiate regeneration at preset total in gallons. Head automatically resets to preset total in gallons for next service run. Electrical lockout prevents simultaneous regeneration of both tanks.
 - d. Demand-Initiated Control: Each twin mineral-tank unit is equipped with automatic-reset-head water meter, in common outlet header, that electrically activates cycle controller to automatically regenerate one mineral tank at preset total in gallons and divert flow to other tank. Automatically repeats with other tank. Electrical lockout prevents simultaneous regeneration of both tanks.
 - e. Demand-Initiated Control: Each mineral tank of multiple mineral-tank unit is equipped with automatic-reset-head water meter that electrically activates cycle controllers to automatically regenerate at preset total in gallons. Head automatically resets to preset total in gallons for next service run. Electrical lockout prevents simultaneous regeneration of more than one tank.
 - f. Demand-Initiated Control: Each multiple mineral-tank unit is equipped with automatic-reset-head water meter, in common outlet header, that electrically activates cycle controller to automatically regenerate one mineral tank at preset total in gallons and divert flow to other tanks. Automatically repeats with other tanks. Electrical lockout prevents simultaneous regeneration of more than one tank.
11. Brine Tank: Combination measuring and wet-salt storing system.
 - a. Tank and Cover Material: Fiberglass, 3/16 inch thick; or molded PE, 3/8 inch thick.

- b. Brine Valve: Float operated and plastic fitted for automatic control of brine withdrawal and freshwater refill.
- c. Size: Large enough for at least four regenerations at full salting.

12. Factory-Installed Accessories:

- a. Piping, valves, tubing, and drains.
- b. Sampling cocks.
- c. Main-operating-valve position indicators.
- d. Water meters.

C. Capacities and Characteristics:

- 1. Water Analysis: Refer to Schedule on Plumbing Drawings

2.2 CHEMICALS

- A. Mineral: High-capacity, sulfonated-polystyrene, ion-exchange resin that is stable over entire pH range with good resistance to bead fracture from attrition or shock.
 - 1. Exchange Capacity: A minimum of 30,000 grains/cu. ft. of calcium carbonate of resin when regenerated with 15 lb of salt.
- B. Salt for Brine Tanks: High-purity sodium chloride, free of dirt and foreign material. Rock and granulated forms are unacceptable.
 - 1. Form: Processed, As Scheduled.

2.3 WATER-TESTING SETS

- A. Description: Manufacturer's standard water-hardness testing apparatus and chemicals with testing procedure instructions. Include metal container suitable for wall mounting.

2.4 SOURCE QUALITY CONTROL

- A. Hydrostatically test mineral tanks before shipment to a minimum of one and one-half times the pressure rating.
- B. Prepare test and inspection reports.

PART 3 - EXECUTION

3.1 WATER SOFTENER INSTALLATION

- A. Equipment Mounting: Install residential water softeners on floor.
 - 1. Maintain manufacturer's recommended clearances.

2. Arrange units so controls and devices that require servicing are accessible.
- B. Equipment Mounting: Install commercial water softeners on concrete base.
1. Maintain manufacturer's recommended clearances.
 2. Arrange units so controls and devices that require servicing are accessible.
 3. Install dowel rods to connect concrete base to concrete floor. Unless otherwise indicated, install dowel rods on 18-inch centers around the full perimeter of concrete base.
 4. For supported equipment, install epoxy-coated anchor bolts that extend through concrete base and anchor into structural concrete floor.
 5. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
 6. Install anchor bolts to elevations required for proper attachment to supported equipment.
 7. Anchor water softener and brine tanks to substrate.
- C. Install seismic restraints for tanks and floor-mounting accessories and anchor to building structure.
- D. Install brine lines and fittings furnished by equipment manufacturer but not specified to be factory installed.
- E. Prepare mineral-tank distribution system and underbed for minerals and place specified mineral into mineral tanks.
- F. Install water-testing sets mounted on wall, unless otherwise indicated, and near water softeners.

3.2 CONNECTIONS

- A. Comply with requirements for piping specified in Section 15140 "Domestic Water Piping." Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Where piping is installed adjacent to equipment, allow space for service and maintenance of equipment.
- C. Install shutoff valves on raw-water inlet and soft-water outlet piping of each mineral tank, and on inlet and outlet headers, with bypass leg and shut-off.
1. Metal general-duty valves are specified in Section 15111 "General-Duty Valves for Plumbing Piping."
 2. Plastic valves are specified in Section 15140 "Domestic Water Piping."
 3. Exception: Water softeners with factory-installed shutoff valves at locations indicated.
- D. Install pressure gages on raw-water inlet and soft-water outlet piping of each mineral tank. Pressure gages are specified in Section 15126 "Meters and Gages for Plumbing Piping."

1. Exception: Water softeners with factory-installed pressure gages at locations indicated.
2. Exception: Household water softeners.
3. Exception: Water softeners in hot-water service.

E. Install valved bypass in water piping around water softeners.

1. Metal general-duty valves are specified in Section 15111 "General-Duty Valves for Plumbing Piping."
2. Plastic valves are specified in Section 15140 "Domestic Water Piping."
3. Water piping is specified in Section 15140 "Domestic Water Piping."
4. Exception: Household water softeners.
5. Exception: Water softeners in hot-water service.

F. Install drains as indirect wastes to spill into open drains or over floor drains.

3.3 IDENTIFICATION

- A. Identify system components. Comply with requirements for identification specified in Section 220553 "Identification for Plumbing Piping and Equipment."

3.4 FIELD QUALITY CONTROL

A. Tests and Inspections:

1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
2. Operational Test: After electrical circuitry has been energized, start units to confirm proper unit operation.
3. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.

B. Water softeners will be considered defective if they do not pass tests and inspections.

C. Prepare test and inspection reports.

3.5 STARTUP SERVICE

A. Engage a factory-authorized service representative to perform startup service.

1. Complete installation and startup checks according to manufacturer's written instructions.

B. Add water to brine tanks and fill with the following form of salt:

1. Commercial Water Softeners: Processed, As scheduled.

- C. Sample water softener effluent after startup and at three consecutive seven-day intervals (total of four samples), and prepare certified test reports for required water performance characteristics. Comply with the following:
1. ASTM D 859, "Test Method for Silica in Water."
 2. ASTM D 1067, "Test Methods for Acidity or Alkalinity of Water."
 3. ASTM D 1068, "Test Methods for Iron in Water."
 4. ASTM D 1126, "Test Method for Hardness in Water."
 5. ASTM D 1129, "Terminology Relating to Water."
 6. ASTM D 3370, "Practices for Sampling Water from Closed Conduits."

3.6 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain water softeners.

END OF SECTION 15469