

KANSAS CITY AREA TRANSPORTATION AUTHORITY

REQUEST FOR PROPOSALS (RFP) #F20-5013-34B  
Network Infrastructure Equipment Refresh  
ADDENDUM #1

Issue Date: August 26, 2020

---

This Addendum is hereby made a part of the Request for Proposals and Project Documents to the same extent as if it was originally included therein and is intended to modify and/or interpret the bidding documents by additions, deletions, clarifications or corrections. The Contractor shall acknowledge receipt of this Addendum in their Proposal on the "Receipt of Addenda" form (herein attached) and shall include the form in Volume III, "Contractual."

---

**GENERAL INFORMATION**

A pre-proposal conference call will be held on **August 28, 2020 at 11am CDT**. Although attendance at this conference is not required, those firms interested in proposing to the RFP are encouraged to attend. A conference line is provided for those that wish to participate.

Teleconference Call-In Information:

Telephone Number: (816) 346-0338  
Participant Code: 0142845

**PROPOSAL CLARIFICATIONS**

Attachment D Price Proposal – page 52 Part D. UPS, Rack, Hardware

1. Are there specific models and quantities you are looking to replace? If not, from the list of servers, storage and core switching equipment, can you provide location ie MDF, IDF1, IDF2, of the equipment?  
No specific models or rack location, etc. We are asking for a complete redesign that will replace all the equipment listed in the RFP.
2. What is the minimum runtime objective for the equipment on UPS?  
All sites are currently on generator backup. UPS based uptime should be specified in the bid response, but no range has been specified.
3. Will the equipment be running at 120V or 208/240V?  
The current systems are 120V. This could change based on the design of the replacement system.
4. Does the facility have 15A, 20A, or 30A circuits?  
Believe it is 20A circuits, will need to confirm.
5. Do you need remote monitoring and temp/humidity sensors?  
Temp and humidity sensors are monitored separately and not required in this RFP.

**END OF ADDENDUM #1**

KANSAS CITY AREA TRANSPORTATION AUTHORITY  
REQUEST FOR PROPOSALS (RFP) #F20-5013-34B  
Network Infrastructure Equipment Refresh

**RECEIPT OF ADDENDA**

Proposers shall return this form when submitting their proposal as part of Volume III – Contractual. The form shall be signed and dated by an authorized representative of the firm. Failure to submit this form may deem the Bidder non-responsive. As additional addenda are issued by, please notate date received below.

---

*We hereby acknowledge that the Addenda noted below have been received and all information has been incorporated into the Invitation for Bid as required.*

**Addendum #1 dated August 26, 2020**                      Date Received \_\_\_\_\_

Addendum #2 \_\_\_\_\_                      Date Received \_\_\_\_\_

Addendum #3 dated \_\_\_\_\_                      Date Received \_\_\_\_\_

Company Name \_\_\_\_\_                      Date \_\_\_\_\_

Address/City/State/Zip \_\_\_\_\_

Authorized Signature \_\_\_\_\_                      Printed Name \_\_\_\_\_

Telephone \_\_\_\_\_                      Fax \_\_\_\_\_                      Email \_\_\_\_\_