

KANSAS CITY AREA TRANSPORTATION AUTHORITY

Request for Qualifications (RFQ) #F23-7013-39A
Kansas City Area Transportation Authority (KCATA)
Construction Administration, Testing, and Inspection Services
For Kansas City Streetcar Riverfront Extension Construction (Package 5)

ADDENDUM #1

Issue Date: December 12, 2023

This Addendum is hereby made a part of the Request for Qualifications and Project Documents to the same extent as if it were originally included therein and is intended to modify and/or interpret the bidding documents by additions, deletions, clarifications, or corrections. The Contractor shall acknowledge receipt of this Addendum on the "Receipt of Addenda" form (herein attached) and shall include the form in their proposal submittal.

CORRECTION

Section 1, "Proposal Schedule" list incorrectly lists the Evaluation/Interview dates. **The correct dates are January 2-5, 2024 (Tentative and if Required).**

PROPOSER QUESTIONS

1. Q: On page 7, Section C "Project Structure and Schedule" please confirm the dates provided in items #3 and #4.

A: Please remove existing paragraphs 3 and 4 and replace them with the following.

"3. Bids for the primary construction project were issued in Mid-March 2023. Bids were received in May 2023 and a BAFO was received from the bidders in September 2023. This bid is anticipated to be awarded to the best qualified bidder as determined by KCATA in December 2023. A construction NTP is anticipated for late January 2024.

4. Construction Administration (CA) services NTP is currently anticipated in the 1st quarter of 2024 with an anticipated completion in late 2025. Project closeout and Integrated Testing, needing Resident Engineer participation is anticipated through Early 2026."

2. Q: Please confirm the role of the project management consultant (Burns & McDonnell / WSP Team) for the Construction Phase. Is the PMC excluded from this solicitation?

A: The Burns & McDonnell / WSP Team will continue to support the Project Management team during the construction phase of the contract. Sub consultants that are on the current contract may be considered for this project if their proposed duties are not the same or pose any conflict. Proposers shall clearly identify the subconsultants' intended scope and the staff

assigned to this project, as well as Proposer's efforts on preventing any perceived or real conflict.

3. Q: Please confirm if the awarded contractor will be responsible for QC obligations (testing and documentation) or if that is part of this contract.

A: Quality Assurance shall be the responsibility of the Pkg 5 consultant. On-site (Quality Control) testing shall be provided by this consultant (Pkg 5) and shall include subgrade and aggregate density tests, concrete sampling and testing, and asphalt compaction testing. Coordination between this consultant (Pkg 5) and the Contractor (Pkg 6) shall be the responsibility of the Contractor (Pkg 6), its representative and the designated testing lab (Pkg 5) when materials are ready for testing, prior to placement of concrete or subsequent materials.

4. Q: On page 19, please confirm the page limit in section 4.3 A. 25 vs. 30 pages.

A: The page limit is 30 pages. Section 4.3.C lists the exceptions to the page count.

5. Q: On page 8, items D. 4. states, "Consultant will be located out of the construction field office." Has this location been established, and will space be provided for our team by the selected Contractor?

A: A space has not been established at this time. This space shall be allocated by KCATA. One office shall be allocated to the Pkg 5 consultant. Normal office amenities shall be available – Wi-Fi, electricity, heating, and air conditioning. Pkg 5 consultant shall supply its required furniture.

6. Q: On page 22, section 4.4 D. states, "The following forms are required and must be provided as part of **Volume III**: Contractual." Please verify if this was intended to indicate "**Volume 2** – Contractual".

A: Yes, the forms are to be submitted as "Volume 2 – Contractual".

7. Q: Will any materials testing (concrete, bituminous asphalt, soil) other than the track weld QA testing listed in 2.1, D. 6. be required under this contract?

A: See response to Question 3 above.

8. Q: Please confirm if Attachment K is only needed for the Prime to complete (no subs).

A: Attachment K, "Non-Collusion Affidavit," is for prime consultants only.

ATTACHMENT

- Receipt of Addenda Form

END OF ADDENDUM

KANSAS CITY AREA TRANSPORTATION AUTHORITY (KCATA)

Request for Qualifications (RFQ) #F23-7013-39A
Kansas City Area Transportation Authority (KCATA)
Construction Administration, Testing, and Inspection Services
For Kansas City Streetcar Riverfront Extension Construction (Package 5)

RECEIPT OF ADDENDA

Proposers shall return this form when submitting their Bid Submittal. The form shall be signed and dated by an authorized representative of the firm. Failure to submit this form may deem the Bidder non-responsive. As additional addenda are issued, please notate date received below.

We hereby acknowledge that the Addenda noted below was received all information has been incorporated into the Bid as required.

Addendum #1 dated December 12, 2023 Date Received _____

Addendum #2 dated _____ Date Received _____

Addendum #3 dated _____ Date Received _____

Company Name _____ Date _____

Address/City/State/Zip _____

Authorized Signature _____ Printed Name _____

Telephone _____ Fax _____ Email _____